

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 46716
Date: 04/23/2024

Detailed Product Description:

Manufacturer: B+N Industries, Inc.

Manufacturer Address: 1409 Chapin Ave. 3rd Floor, Burlingame, CA 94010


Model Name: TLKS-5050 Wall-Mounted Louver Siding System

Maximum Design Load: +75 PSF, -75 PSF

Installation Drawings # 23-13F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, uplift pressure, spacing and anchor type refer to installation drawings.					
Comparative analysis used <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
TAS-202	Uniform Static Air Press.	Intertek	3/16/2023	P0688.01-119-18	Tanya A. Dolby, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

<p>Evaluation Report Engineer:</p> <p>Jalal Farooq PE # 81223 Al-Farooq Corporation EB # 3538</p>	 <p>Sealed: 4/30/24</p>
--	---